

POOL / SPA SELF INSPECTION CHECKLIST

DOORS/GATES/ENCLOSURE	YES	NO	N/A
Gates self-latching & self-closing			
Gate opens outwards away from pool			
Emergency exit designated with sign & functional			
Fence/gate meets gap requirements (4")			
Fence/gate meets minimum height requirements (4' or 5')			
Climbing hazards not present within 5 feet of fence exterior			
WATER TREATMENT/QUALITY	YES	NO	N/A
Adequate disinfectant			
pH maintained (7.2 - 7.8)			
Cyanurate (100 ppm)			
Water temperature (104°F)			
Combined chlorine (0.4 ppm) (optional)			
Water clarity maintained with main drain visible			
Pool free from algae growth & debris/Proper water level			
Meets bacterial/chemical/indoor air standards			
SAFETY EQUIPMENT	YES	NO	N/A
Lifeguard(s) present with certification/first aid kit available (if applicable)			
Rescue pole (12 ft) with attached body hook, visible & accessible			
Life ring with attached rope, mounted & visible			
Spa emergency shut-off switch, accessible & functional			
Suction outlet fittings properly installed & in good repair (VGB)			
Secondary anti-entrapment device in place (VGB)			
SAFETY SIGNS	YES	NO	N/A
Occupant load (4")			
"No Diving" (4")			
"Warning-No Lifeguard on Duty" (4")			
No children under 14 without an adult present (>1")			
Artificial Respiration/CPR (1/4")			
Emergency 911/ local emergency contact /site address (4")			
Spa caution (1")			
Emergency shut-off (1")			
"No Use of Pool After Dark" (4")			
"Keep Closed" on gate exteriors (4")			
Diarrhea warning (1")			
Wave pools (1")			
Spray ground (4")			
Gaseous chlorine (4")			

SUPERVISION	YES	NO	N/A
Operating records available/complete			
Approved pool water test kit available			
No employee/patron with a communicable disease			
POOL STRUCTURE	YES	NO	N/A
Pool shell maintained & in good repair			
Water line tiles clean & in good repair			
Coping or equivalent present & good repair			
Depth markers installed, readable, accurate & in good repair			
Depth marking line (break-in-slope) present as required			
No protrusions/projections/decorative designs present			
Skimmer/overflow system assembly operational & complete			
Water return inlet fittings in good repair			
Lighting operational, properly installed & in good repair			
Hand & grab rails/stairs present & in good repair			
Ladders/Step holes properly installed/maintained			
Deck in good condition, free of slip/trip hazards			
4 ft. of unobstructed deck around perimeter of pool & 50% spa			
Diving board properly maintained			
No electrical hazards present in pool area			
EQUIPMENT ROOM	YES	NO	N/A
Accurate flow meter installed & functional			
Pressure gauges/valves installed & functional			
Pumps functional when pool is open & turnover is met			
Automatic disinfectant feeder properly installed & functional			
Electrical or other hazards not present in equipment area			
Filter maintained & properly installed			
Back flow prevention provided as required			
Proper disposal of wastewater			
Light switches & GFCI installed & maintained			
Gas chlorination maintained as required			
Pipes labeled with direction of flow & system identification			
ANCILLARY AREAS	YES	NO	N/A
Restrooms/showers clean/functional/stocked/hot water (Max 110°F)			
Drinking fountain clean & maintained			
Hose bib(s) installed with vacuum breakers as required			
Miscellaneous:			