COUNTY OF SAN MATEO
HEALTH SYSTEM

SAN MATEO COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
Recreational Health Program
2000 Alameda de las Pulgas, Suite 100
San Mateo, CA 94403
Phone (650) 372-6200 Fax (650) 627-8244
www.smchealth.org/pools

MAINTAIN DATA AND RECORDS FOR AT LEAST 2 YEARS

WATER REQUIREMENTS FOR POOL		WATER REQUIREMENTS FOR SPA, WADING POOL, AND SPRAY GROUND		TESTING REQUIREMENTS	
Temperature (TEMP)	104°F (Maximum)	Temperature	104°F (maximum)	TEMP:	*Daily for heated pool/spa*
Free Chlorine (FC)	1.0-10.0 Ppm	Free Chlorine	3.0-10.0 ppm	FC, CC & pH:	*Daily*
	2.0-10.0 Ppm W/Cyanuric	pH	7.2-7.8	(exemption: 2x/week, ≤4 days apart if < 25 units)	
pH	7.2-7.8	Cyanuric Acid	100 ppm (maximum)	CYA:	*monthly*
Cyanuric Acid (CYA)	100 Ppm (Maximum)	Water Clarity	Clean and Clear	**Other Recommended Chemical Range:**	
Water Clarity (WC)	Clean and Clear			Total Alkalinity:	60-180ppm
				Calcium Hardness:	200-400ppm
				Combined Chlorine (CC):	0.4 ppm

Date/ Time	Tech/ Engineer	Water Temp/ Clarity	Free Chlorine	Combine Chlorine	pH	Cyanuric Acid	Total Alkalinity	Calcium Hardness	Filter Pressure	Vacuumed	Back-Washed/ Filter Cleaned	Skimmer Baskets Cleaned	Chemical Added